

**Big-Ox Communication – Conference Call No. 48**  
**Meeting Minutes**  
Wednesday, January 25, 2017

**1. Short Term Plan Action Items**

- a. Tideflex valves
  - i. All are installed - installed and having no issues
- b. Temporary Pump Station
  - i. Bennet Ave Road Condition – no issues
  - ii. City operations
  - iii. Security – game cameras are all working / working on the fence option as did get ahold of Cardis fence
  - iv. Protection from freezing - heat trace tape has been installed for weather
  - v. Back-up 3<sup>rd</sup> Pump – ready to go if needed
- c. McClure Additional Services- been approved at the council meeting

**2. Long Term Plan Action Items**

- a. Separate forcemain from Roth Industrial Park to Bennet Lift
  - i. Easements ( to title company – work done )
  - ii. Pump around Bennet
  - iii. EDA funding (fact sheet and waiting on Tammy at City- plans should be ready by next Council meeting)

**3. Sampling Update**

- a. H2S Levels at Bennet have come back down to less than 10 ppm average
  - Received ACS results and will send out
- b. Reduce sampling points ( 4 points Now)

**4. Big Ox Status Report**

No one is one

**5. Sioux City Status Report**

**6. Public Relations**

- a. 10:30 meeting today

**7. Other Issues**

- a. SO<sub>2</sub> testing
- b. Sheet Rock testing